AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE		PAGE OF PAGES
					1 2
		4. REQUISITION/PURG	J NASE DEC. NO.	L s ppousors	
2. AMENDMENT/MODIFICATION NO. <b>02</b>	3. EFFECTIVE DATE 21 Aug 2000			3	O. (If applicable)
6. ISSUED BY	21 Aug 2000	FQ524001180200 AJJY 00-7000  7. ADMINISTERED BY (If other than Item 6)			
CODE		] / ADMINISTERED BT	(1) omer man nem c	CODE [	
36th Contracting Squadron		]			
Unit 14040					
APO AP 96543-4040					
POC:SSGT Nancy Alessandrini, PH:(671)366	6-2357, Fax:(671)366-3242				
8. NAME AND ADDRESS OF CONTRACTOR (No., stree	t, county, State and Zip Code)		(√)   9A. AMEN	IDMENT OF SOLI	CITATION NO.
ALL PROSPECTIVE OFFERORS			133-00-R0012	2	
			1 1	D (SEE ITEM 11)	
				UL 2000	
			10A. MOD	IFICATION OF CO	NTRACT/ORDER NO.
			10B. DAT	ED (SEE ITEM 13)	
CODE	FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
The above numbered solicitation is amended a				is extended	is not extended.
Offers must acknowledge receipt of this amendmen	t prior to the hour and date spec	rand date specified for a	receipt of Offers E or as amended, by	one of the follow	ving methods:
• .	•		-		_
(a) By completing Item 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDG-					
MENT TO BE RECEIVED AT THE PLACE DESIGN					
IN REJECTION OF YOUR OFFER. If by virtue of the					
letter, provided each telegram or letter makes refere		amendment, and is rece	ived prior the oper	ning hour and da	ite specified.
12. ACCOUNTING AND APPROPRIATION DATA (If requi	irea)				_
N/A					\$
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,					
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
(1) A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CON-					
TRACT/ORDER NO IS ITEM 10A					
Ш					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office,					
appropriation data, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS	S ENTERED INTO PURSUANT	TO AUTHORITY OF:			
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor is not, is required to sign this document and return copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)					
077 P. 67 A 67 A					
SEE PAGE 2 OF 2					
•					
		,			
Except as provided herein, all terms and conditions	of the document referenced in	Item 9A or 10A as here	tofore changed re	emains unchang	ed and in full force
and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE	OF CONTRACTING	OFFICER (Type or	print)
15B. CONTRACTOR/OFFEROR	15C DATE SIGNED	16B. UNITED STATES (	OF AMERICA		16C. DATE SIGNED
		BY			

(Signature of person authorized to sign)

(Signature of Contracting Officer)

## **COVER SHEET**

 Change the Solicitation Closing Date to 31 AUG 2000, 4:00 P.M. in lieu of 23 AUG 2000, 4:00 P.M.

## **STANDARD FORM 1442**

2. Change paragraph 13A. to read as follows:

Sealed offers in original and <u>one</u> copies to perform the work required are due at the place specified in item 8 by 4:00 P.M. LOCAL TIME **31 AUG 00**. If this is a sealed bid solicitation, offers will be publicly opened at that time. Sealed envelopes containing offers shall be marked to show the offeror's name and address, the solicitation number and the date and time offers are due.

## **QUESTIONS AND ANSWERS:**

3. Question: Regarding the rubber removal amounts – CLINS 0001, 0002, and 0003, the amounts seem very low. Could the engineer have meant square yards instead of square feet?

Answer: No, square feet is correct. The quantities listed on the bid schedule are estimates only.

- 4. Question: Was this striping previously performed in house or by a contractor? Answer: Some striping has been performed in house, and some has been performed by a contractor.
- 5. Question: Will there be any storage space available on base for the successful contractor? Answer: Yes. The issue of storage space will be addressed at the Pre-Construction Conference and coordinated with the Civil Engineer Inspector.
- Question: Is there lodging available on base for the successful contractor? Answer: No.
- 7. Question: What type material does the areas to paint and rubber removal made of (concrete, asphalt, etc)?

Answer: The entire North Runway is asphalt, and the majority of the South Runway is asphalt except for the approach ends(1200') which are a combination of concrete and asphalt. All taxiways are asphalt except Taxiway Kilo and portions of Taxiway Foxtrot. There are several concrete aprons on the South (SR-1, SR-2, SR-6, SR-7) on the South portion of the airfield that were recently painted. All other aprons/parking spots are asphalt.

8. Question: Are the rates of removal for paint and rubber removal (10,000sq. ft. per hour) accurate?

Answer: Yes, the rates for removal are correct.